



STATYBOS PRODUKCIJOS
SERTIFIKAVIMO CENTRAS

PERFORMANCE RESULTS

Reovesi OÜ
EN 12566-3:2005+A2:2013

“Small wastewater treatment systems for up to 50 PT-Part 3”

Small wastewater treatment system Reovesi-bio7

Plant consists of 1 horizontal tank.

Biological waste water treatment process with activated sludge

Nominal hydraulic daily flow	0,65 m ³ /d
Material	polyethylene
Watertightness	pass

Treatment efficiency ratios (at tested organic daily load BOD₅ 0,228 kg/d)

	Efficiency (%)	Effluent (mg/l)
BOD ₅	98,3	5,82
COD	95,3	32,9
SS	98,1	6,50
N _{kj}	97,4(97,7*)	2,11(2,12*)
N _{tot}	29,0(42,2*)	56,9(54,1*)
P	30,0	5,51
NH ₄ -N	99,4(99,5*)	0,449(0,480*)
NO ₂ -N		0,726(0,816*)
NO ₃ -N		54,1(51,1*)

Electrical energy consumption: 1,71kWh/d is average rate during nominal sequences.
1,71 kWh/d is average rate during all test period.

Number of desludging 0

* - values from calculation are excluded if temperatures in the reactor are below 12 °C

Performance tested by:

SPSC - Statybos produkcijos sertifikavimo centras
Linkmenų str. 28
LT-08217 Vilnius
Lithuania

Notified Body number: 1397

Director Valdemaras Gauronaskis

May 2020

Reg. Nr. 44_2020